



Development Service Center

Hipolito Olmos C.B.O. Building Division
7351 Rosanna Street, Gilroy, CA 95020
Phone: 408 846-0451 Fax: 408 846-0429
Visit us: www.cityofgilroy.org

2019 CAL Green
Residential
Mandatory
Measures Checklist

PURPOSE:

THE 2019 CALIFORNIA GREEN BUILDING STANDARDS CODE (CALGREEN) APPLIES TO ALL NEWLY CONSTRUCTED HOTELS, MOTELS, LODGING HOUSES, DWELLINGS, DORMITORIES, CONDOMINIUMS, SHELTERS, CONGREGATE RESIDENSES, EMPLOYEE HOUSING, FACTORY BUILT HOUSING, AND OTHER TYPES OF DWELLINGS WITH SLEEPING ACCOMODATIONS AND NEW ACCESSORY BUILDINGS ASSOCIATED WITH SUCH USES. THE FORM CONSISTS OF 3 SECTIONS (CHECKLISTS, DESIGN VERIFICATION, AND IMPLEMENTATION VERIFICATION). PLEASE COMPLETE THIS FORM FOLLOWING THE INSTRUCTIONS BELOW.

Project Name: _____

Project Address: _____

Project Description: _____

INSTRUCTIONS:

1. The owner/owner's agent may employ a professional who is experienced with the 2019 CALGREEN to verify and assure that all required work described herein is properly planned and implemented in the project.
2. She/he needs to certify the mandatory features shown in the checklist in Section A by signing section B and submit a copy to the Building Division as part of the plan submittal for permitting.
3. Prior to final inspection by the Building Division, she/he needs to check off column B, sign and date section C located at the end of this checklist and submit the completed form to the building inspector.

SECTION A: CHECKLIST

This checklist applies to newly constructed buildings, additions or alterations of existing residential buildings where the addition or alteration increases the building's conditioned area, volume, or size. The requirements shall only apply to and/or within the specific area of the addition or alteration. 2019 CGBSC 301.1.1)

Measures in this checklist apply to either low-rise residential buildings, high-rise residential buildings, or both, unless noted with the following banner (2019 CGBSC 301.2):

[LR] = Measures applicable to low-rise buildings only

[HR] = Measures applicable to high-rise buildings only

Residential Feature or Measure	Column A	Column B
	Project Request	Verification
RESIDENTIAL MANDATORY MEASURES		
Site Development (4.106)		
<p>Projects Less Than One Acre: Projects which disturb less than one acre of soil and are not part of a larger common plan of development which in total disturbs one acre or more, shall manage storm water drainage during construction CGBSC 4.106.2.</p> <p>Projects One Acre or More SWPPP: Newly constructed projects or additions shall comply with Gilroy Municipal Code Chapter 27C & 27D for erosion and sediment controls, the Central Coast Regional Water Quality Control Board (CCRWQCB) and Storm water NPDES Permit requirements.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>Construction plans shall indicate how the site grading or drainage system will manage all surface water flows to keep water from entering buildings CGBSC 4.106.3.</p> <p>Exception: Additions and alterations not altering the drainage path.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>Electric vehicle (EV) charging for new construction. New construction shall comply with sec. 4.106.4.1, 4.106.4.2 and 4.106.4.3 to facilitate future installation and use of EV chargers. Electric vehicle supply equipment (EVSE) shall be installed in accordance with California Electrical Code (CEC), Article 625.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>One and Two Family Dwellings and Townhouses EV: CGBSC 4.106.4.1. Multifamily Dwellings EV: CGBSC 4.106.4.2.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
ENERGY EFFICIENCY		
<p>For the purposes of mandatory energy efficiency standards in this code, the California Energy Commission will continue to adopt mandatory standards CGBSC 4.201.1.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
WATER EFFICIENCY AND CONSERVATION		
Indoor Water Use (4.303)		
<p>Water closets. The effective flush volume of all water closets shall not exceed 1.28 gpf. Tank-type water closets shall be certified to the performance criteria of the U.S. EPA Water Sense Specification for Tank-type Toilets.</p> <p>Note: The effective flush volume of dual flush toilets is defined as the composite, average flush volume of two reduced flushes and one full flush.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>Urinals. The effective flush volume of wall mounted urinals shall not exceed 0.125 gpf and other urinals shall not exceed 0.5 gpm.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>Single showerheads. Showerheads shall have a max. flow rate of not more than 1.8 gpm at 80 psi. Showerheads shall be certified to the performance criteria of the U.S. EPA Water Sense Specification for Showerheads.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>Multiple showerheads serving one shower. When a shower is served by more than one showerhead, the combined flow rate of all the showerheads and/or other shower outlets controlled by a single valve shall not exceed 1.8 gpm at 80 psi, or the shower shall be designed to allow only one shower outlet to be in operation at a time.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>Residential lavatory faucets. The max. flow rate of residential lavatory faucets shall not exceed 1.2 gpm at 60 psi. The min. flow rate of residential lavatory faucets shall not be less than 0.8 gpm at 20 psi.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Residential Feature or Measure	Column A	Column B
	Project Request	Verification
Lavatory faucets in common and public use areas. The max. flow rate of lavatory faucets installed in common and public use areas (outside of dwellings or sleeping units) in residential buildings shall not exceed 0.5 gpm at 60 psi.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Metering faucets. Metering faucets when installed in residential buildings shall not deliver more than 0.2 gallons per cycle.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Kitchen faucets. The max. flow rate of kitchen faucets shall not exceed 1.8 gpm at 60 psi.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Outdoor Water Use (4.304)		
New construction projects with an aggregate landscape area equal to or greater than 500 sq. ft. that requires a building or landscape permit, plan check, or design review or rehabilitated landscape projects with an aggregate landscape area of 2,500 square feet or larger that requires a building or landscape permit, plan check, or design review shall comply with a local water efficient landscape ordinance or the current California Department of Water Resources' Model Water Efficient Landscape Ordinance (MWELO), whichever more stringent.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
MATERIAL CONSERVATION AND RESOURCE EFFICIENCY		
Enhanced Durability and reduced Maintenance (4.406)		
Rodent proofing. Annular spaces around pipes, electric cables, conduits, or other openings in sole/bottom plates at exterior walls shall be protected against the passage of rodents by closing such openings with cement mortar, concrete masonry or similar method acceptable to the enforcing agency.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Construction Waste Reduction, Disposal and Recycling (4.408)		
Construction or demolition projects in excess of 5000 sq. ft per local ordinance # 2007-20 shall have a minimum of 65% of the non-hazardous construction waste generated at the site diverted from the land field by recycling or salvaging for reuse in accordance with either Section 4.408.2, 4.408.3 or 4,408.4. 4.408.2 Construction Waste Management Plan (WPM). Submit a WPM for approval prior to construction or demolition permit issuance. 4.408.3 Waste management company. Utilize a waste management company, approved by the enforcing agency, which can provide verifiable documentation that the percentage of construction demolition waste material diverted from the landfill complies with Section 4.408.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building Maintenance and Operation (4.410)		
O&M Manual: At the time of final inspection, a manual, compact disc, web-based reference or other media acceptable to the enforcing agency which includes all of the following shall be placed in the building operation and maintenance manual shall be available in the building at the time of final inspection.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Recycling by Occupants: Where 5 or more multifamily dwelling units are constructed on a building site, provide readily accessible area(s) that serves all buildings on the site and is identified for the depositing, storage and collection of non-hazardous materials for recycling, including (at a minimum) paper, corrugated cardboard, glass, plastics, organic waste, and metals, or meet a lawfully enacted local recycling ordinance, if more restrictive.	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Residential Feature or Measure	Column A	Column B
	Project Request	Verification
ENVIRONMENTAL QUALITY		
Fireplaces (4.503)		
Bay Area Air Quality Management District: Effective November 1, 2019 – “No wood-burning devices of any kind may be installed in new homes or buildings being constructed in the Bay Area”. “Bay Area residents who begin a chimney or fireplace remodeling project that costs over \$15,000 and requires a building permit will only be allowed to install a gas-fueled, electric or EPA-certified device”.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Gas fireplace shall be a direct-vent sealed-combustion type.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Pollutant Control (4.504)		
At the time of rough installation, during storage on the construction site and until final startup of the heating, cooling and ventilation equipment, all duct and other related air distribution component openings shall be covered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Adhesives, sealants and caulks shall be compliant with VOC limits as shown in Table 4.504.1 or 4.504.2 as applicable.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Aerosol adhesives and smaller unit sizes of adhesives and sealant or caulking compounds shall comply with statewide VOC standards and other requirements.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Paints, stains and other coatings shall be compliant with VOC limits as shown in Table 4.504.3.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Aerosol paints and coatings shall meet the Product-Weighted MIR limits for ROC and comply with the BAAQMD percent VOC by weight of product limits of Regulation 8, Rule 49.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
All carpet shall meet the testing and project requirements per sec. 4.504.3. All carpet installed in the building interior shall meet the requirements of the Carpet and Rug Institute’s Green Label Plus program, California Department of Public Health, NSF/ANSI 140 at the Gold level, or Scientific Certifications Systems Indoor Advantage Gold. All carpet cushion installed in the building shall meet the requirements of the Carpet and Rug Institute’s Green Label program. All carpet adhesive shall meet the requirements of Table 4.504.1.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
At least 80% of floor area receiving resilient flooring shall comply with the requirements per sec. 4.504.4.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Hardwood plywood, particleboard and medium density fiberboard (MDF) used on interior or exterior of the building shall comply with formaldehyde emission limits per Table 4.504.5.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Documentation shall be provided to the City building inspector verifying that compliant materials have been used.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Interior Moisture Control (4.505)		
Concrete Slab Foundations: Concrete slab foundations required to have a vapor retarder by the California Building Code or the California Residential Code shall have a capillary break installed in compliance with CGBSC 4.505.2.1.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building materials with visible signs of water damage shall not be installed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Moisture content of building materials used in wall and floor framing shall not to exceed 19% before enclosure. Moisture content shall be verified in compliance	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Residential Feature or Measure	Column A	Column B
	Project Request	Verification
with CGBSC 4.505.3.		
Insulation products which are visibly wet or have a high moisture content shall be replaced or allowed to dry prior to enclosure.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Indoor Air Quality and Exhaust (4.506)		
Bathroom exhaust fans shall be ENERGY STAR rated and ducted to terminate outside.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Unless functioning as a component of a whole house ventilation system, bathroom exhaust fans must be controlled by a humidity control adjustable between a relative humidity range of 50% - 80%.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Environmental Comfort (4.507)		
Duct systems are sized, designed, and equipment is selected using the following methods: 1. Establish heat loss and heat gain values according to ANSI/ACCA 2 Manual J-2016 (Residential Load Calculation), ASHRAE handbooks or other equivalent design methods. 2. Size duct systems according to ANSI/ACCA 1 Manual D-2016 (Residential Duct Systems) or other equivalent design software or methods. 3. Select heating and cooling equipment according to ANSI/ACCA 3 Manual S-2014 or other equivalent design methods.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
INSTALLER AND SPECIAL INSPECTOR QUALIFICATIONS		
Qualifications (702)		
HVAC system installers are trained and certified in the proper installation of HVAC systems.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Special inspectors employed by the owner or owner's agent shall demonstrate competence for the particular type of inspection to be performed and shall have a certification or education in the area closely related to the primary job function that is acceptable to the enforcing agency.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Verifications (703)		
Verification of compliance with this code may include construction documents, plans specifications builder or installer certification, inspection reports, or other methods acceptable to the enforcing agency, which show substantial conformance.	<input checked="" type="checkbox"/>	<input type="checkbox"/>

CALGREEN SIGNATURE DECLARATIONS

SECTION B: DESIGN VERIFICATION

Complete all lines and submit checklist with the plans and building permit application to the Building Division.

The owner/owner's agent and professional responsible for compliance with CALGREEN Standards have certified that the items checked above are hereby incorporated into the project plans and will be implemented into the project in accordance with the requirements set forth in the 2019 CALGREEN as adopted by the City of Gilroy.

Owner's Name: _____ Owner's Signature: _____

CALGREEN COMPLIANCE Professional's Name: _____

CALGREEN COMPLIANCE Professional's Signature: _____

CALGREEN COMPLIANCE Profession's Contact (Email & Phone): _____

SECTION C: IMPLEMENTATION VERIFICATION

Complete, sign, and submit the completed checklist along with SECTION B and C to the Building Inspector prior to Final inspection.

I have inspected the work and have received sufficient documentation to verify and certify that the project identified above was constructed in accordance with CALGREEN checklist and in accordance with the 2019 CALGREEN as adopted by the City of Gilroy.

CALGREEN COMPLIANCE Professional's Name: _____

CALGREEN COMPLIANCE Professional's Signature: _____

CALGREEN COMPLIANCE Profession's Contact (Email & Phone): _____
